

Clear Fork Interceptor Drainage Basin Flows		
Planning Period	Average Daily Flow (MGD)	Peak Wet Weather Flow (MGD)
2020	0.44	1.74
2030	0.55	2.21
Buildout	0.97	3.89

Source: 2022 Water/Wastewater Impact Fee Analysis

CITY OF ALEDO
EXHIBIT A: CLEAR FORK INTERCEPTOR

LEGEND

- Clear Fork Interceptor
- Sewer Shed
- Under Design Lift Station
- Under Design Force Main
- Existing Wastewater System
- Lift Station

Wastewater Treatment Plant6" and Smaller Wastewater Line8" and Larger Wastewater LineForce MainParcelCity Limit